

Certificate of Product Approval

Certificate Number: 1430a

Issue: 01

Firetrace Limited

Unit 22
Knightsdale Road
Ipswich
Suffolk
IP1 4JJ
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Direct Low Pressure (DLP) Application Fixed Fire Suppression Systems
(see attached appendix for details)

Standards

LPS 1666: Issue 1.0

Requirements and test procedures for the LPCB approval of direct low pressure (DLP) application fixed fire suppression systems, using heat sensitive pneumatic detection tubing, for the protection of small defined volume unoccupied enclosures.

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Joe Milton
Verifier

16 June 2017
Date of Issue

16 June 2017
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1430a Firetrace Limited

Issue: 01

Firetrace® Ltd 3M™ Novec™ 1230 Direct Low Pressure (DLP) Application Fixed Fire Suppression Systems

Product Name	Container Size	Description	Detector Tube	Ventilation (Enclosed or Open Vents)	Air Flow (Forced / Natural)	LPCB Ref. No
2Kg Firetrace®	2 kg	2 kg Novec™ 1230 DLP system	FT0115	Enclosed only	None	1430a/01

Notes:

1. Firetrace Ltd. 3MTM NovecTM 1230 DLP Systems shall be configured, installed, serviced and maintained in accordance with Firetrace Ltd. System Manual FIRETRACE LPCB 1116 – 04/03/2017.
2. These systems are intended solely to provide enhanced local fire protection. They are not intended for use as whole room or building fire protection systems.
3. The systems use a single method for detection and delivery of the extinguishing agent to the activation point.
 - System operation pressure: 12 bar @ 20°C.
 - System operation temperature range: -20°C to +60°C.

This certificate and appendix is maintained and held in force through regular surveillance activities

J. Mit.

Signed for BRE Global Ltd.

Joe Milton
Verifier

16 June 2017
Date of Issue

16 June 2017
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre